




Product Service

CERTIFICATE

No. Z2 108181 0003 Rev. 02

Holder of Certificate: **ET SOLAR POWER HONGKONG LIMITED**
Room 01,21/F, XINGFA Commercial Building
9th Tobacco Factory Street
Mong Kok
HONG KONG

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061917001-03

Valid until: 2026-01-04

Date, 2021-01-12

(David Bo)

Model(s):
156.75 cell modules
ET-M672xxxWW, ET-M672xxxWB (xxx=370 to 390 in step of 5)
ET-M660xxxWW, ET-M660xxxWB (xxx=310 to 325 in step of 5)
158.75 cell modules
ET-M672BHxxxWW, ET-M672BHxxxWB (xxx=385 to 420 in step of 5)
ET-M660BHxxxWW, ET-M660BHxxxWB (xxx=320 to 350 in step of 5)
ET-M672BHxxxBB (xxx=385 to 410 in step of 5)
ET-M660BHxxxBB (xxx=320 to 340 in step of 5)



CERTIFICATE

No. Z2 108181 0003 Rev. 02

ET-M672BHxxxTW (xxx=385 to 420 in step of 5)
 ET-M660BHxxxTW (xxx=325 to 350 in step of 5)
 166 cell modules
 ET-M672BHxxxWW, ET-M672BHxxxWB (xxx=425 to 455 in step of 5)
 ET-M660BHxxxWW, ET-M660BHxxxWB (xxx=355 to 375 in step of 5)
 ET-M672BHxxxBB (xxx=415 to 445 in step of 5)
 ET-M660BHxxxBB (xxx=345 to 370 in step of 5)
 ET-M672BHxxxTW (xxx=435 to 455 in step of 5)
 ET-M660BHxxxTW (xxx=360 to 375 in step of 5)
 The suffix WW stands for silvery frame and white backsheet
 The suffix WB stands for black frame and white backsheet
 The suffix BB stands for black frame and black backsheet
 The suffix TW stands for silvery frame and transparent backsheet
 xxx stands for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Production Facility(ies):

101631, 003600